



Universidad
Politécnica
de Cartagena



Escuela
Técnica
Superior

Ingeniería
Naval y
Oceánica

TRANSPORT OF LIQUEFIED HYDROGEN: RISK ANALYSIS OF THE UNLOADING PROCESS AT THE SHIP TERMINAL

*TRANSPORTE DE HIDRÓGENO LICUADO: ANÁLISIS DE
RIESGOS EN EL PROCESO DE DESCARGA EN LA
TERMINAL DE BUQUES*

AUTHORS

- Sánchez Sánchez, Julián – UPCT
- Pellitero Pérez, José – Pavilion Energy
- Dr. Mascaraque-Ramírez, Carlos – UPCT
- Dr. Gutierrez Romero, Jose Enrique – UPCT



TRANSPORT OF LIQUEFIED HYDROGEN: RISK ANALYSIS OF THE UNLOADING PROCESS AT THE SHIP TERMINAL

WHY?

Environmental protection and the fight against climate change have driven the search for sustainable fuels, with hydrogen standing out as a promising alternative due to its high energy density and clean combustion. However, its **storage and transport present significant safety challenges, especially in its liquefied form (LH₂), due to its low boiling temperature and low heat of vaporization.** Ensuring its safe use is key to its deployment in sectors such as energy and transport.




HOW?

To **minimize the risks associated with hydrogen storage and transport**, risk analysis methodologies such as **HAZOP, HAZID and FMEA** are applied. These tools allow hazards to be identified, potential system failures to be assessed and preventive measures to be designed. Their implementation helps to optimize the safety and viability of hydrogen as an energy carrier, ensuring its sustainable and reliable development on a large scale.

Risk Assessment Methodologies



Risk Management is essential
Advanced safety protocols are key
Innovative research is crucial



SHIP & TERMINAL


DESCRIPTION:

The vessel considered in this study is a Liquid Hydrogen Carrier (LHC) with a capacity of approximately **160,000 m³** and an overall length of approximately **300 meters**. The LHC will transport the liquid at approximately -253°C, atmospheric pressure and a ratio of liquid/gas volume of approximately 800 times.


This vessel is based on real vessels such as the Suiso Frontier as well as others that are in the project and design phase, although the size of the vessel is larger than those currently built, and it is a theoretical model that responds to a volume comparison of current LNG carriers.






SHIP & TERMINAL




SHIP & TERMINAL






HAZOP METHODOLOGY



HAZID METHODOLOGY



FMEA METHODOLOGY



HAZOP: Use Case

Case	Parameter word	Guide Word	Possible cause of deviation	Consequence	CONSEQUENCE	PROBABILITY	RISK			
1	Flow in pipe LH2. Operation 1	NO	LH2 Spray Pump malfunction	No fluid circulation due to pump malfunction. No cool down of required lines.	1	3	3			
2	Flow in pipe LH2. Operation 1	NO	Hydraulic Valves Failed to Open: Failed to open CS301	No fluid circulation due to hydraulic valves closed. No cool down of required lines.	1	2	2			
3	Flow in pipe LH2. Operation 1	NO	Hydraulic Valves Failed to Open: Failed to open CS303	No fluid circulation due to hydraulic valves closed. No cool down of required lines.	1	2	2			
4	Flow in pipe LH2. Operation 1	NO	Hydraulic Valves Failed to Open: Failed to open CS071/072	No fluid circulation in liquid crossover. No cool down of required lines.	1	2	2			
5	Flow in pipe LH2. Operation 1	NO	Hydraulic ESD Valves leak	Possible creation of explosive atmosphere	5	3	15			
Operator Intervention		Independent safeguards		Priority	Recommended action	Comments to recommended action	Mitigation Contingency	CONSEQUENCE	PROBABILITY	RISK
Operator can see no fluid circulation & signal of pump running. Operator should control fluid recirculation to tank and try to restore spray pump availability or start another spray from other tank.		Control system will identify sequence failure or pump malfunction		Medium	Check Alarms of Spray Pump Pumps and piping systems (interconnected) redundancy	This is not a serious operational situation since it simply does not open the hydraulic valve at the tank outlet line. First the recirculation through the CS300 line should be foreseen and if not a logical protection for not having circulation downstream of the hydraulic valve and the pump running, the pump should be commanded to emergency shutdown immediately to avoid a possible leakage through the LH2 flange by the flange upstream of the CS301 valve that does not open.	Contingency	0	3	0
Operator can see no fluid circulation & alarm no pressure or no flow at any section line.		Control system will identify sequence failure and send Trip Spray pump.		Medium	Check Hydraulic system & Valves. Check automatic sequence.	This is not a serious operational situation since it simply does not open the hydraulic valve at the tank outlet line. First the recirculation through the CS300 line should be foreseen and if not a logical protection for not having circulation downstream of the hydraulic valve and the pump running, the pump should be commanded to emergency shutdown immediately to avoid a possible leakage through the LH2 flange by the flange upstream of the CS301 valve that does not open.	Mitigation / Contingency	0	1	0
Operator can see no fluid circulation & alarm no pressure or no flow at any section line.		Control system will identify sequence failure and first open CS300 to recirculate LH2 to tank, if opening valve CS300 failed then Trip Spray pump. The final safeguard is to open manually the CS304. Recirculation valve CL304 should be open during cooldown lines.		Low	Check Hydraulic system & Valves. Check automatic sequence.	This is not a serious operational situation since it simply does not open the hydraulic valve at the tank outlet line. First the recirculation through the CS300 line should be foreseen and if not a logical protection for not having circulation downstream of the hydraulic valve and the pump running, the pump should be commanded to emergency shutdown immediately to avoid a possible leakage through the LH2 flange by the flange upstream of the CS301 valve that does not open.	Mitigation / Contingency	0	1	0
Operator can see no fluid circulation in crossovers lines		Automatically open CS300 to recirculate LH2 to tank to avoid overpressure in cross over lines		Medium	Check Hydraulic system & Valves. Check automatic logic sequence.	This is not a serious operational situation since it simply does not open the hydraulic valve that distributes the LH2 to one side of the vessel or the other in the crossover. Provision should first be made for recirculation through the line from the CS300 to the tank and if recirculation to the tank is not possible and the pump running, the pump should be commanded to emergency shutdown immediately and thus avoid overpressure in the crossover and prevent a possible leak through any of the LH2 flanges provided.	Mitigation / Contingency	0	1	0
Operator can see alarm hazardous gas detection & close hydraulics valves CS071/CS072 to isolate the final section line prior to ESD Valve		Function logic that close CS071/CS072 if gas hazardous gas leak is detected		High	Isolate with manual valve this connection to shore	This is a high risk situation. To quantify the risk, it would be interesting to quantify the amount of gas that could escape through the internal leakage of the valve. It could be known by quantifying the amount of LH2 in the section considered coming from the previous cut-off valve and a simulation of gasification on deck from this valve. Provide safety distances to these risk points during operation. Provide for inspections and maintenance of critical valves.	Mitigation / Contingency	4	2	8

HAZOP: Example scenarios

Node 1 field and record selection


CASE	POSSIBLE CAUSE OF THE DEVIATION	CONSEQUENCE	RISK
1. Flow rate in LH2 pipeline. Operation 1 - No flow	Leakage at flange or fitting	Possible creation of an explosive atmosphere.	15
2. Flow rate in LH2 pipe. Operation 1 - Excessive flow rate	LH2 pump malfunction	Excessive flow circulation. Process out of parameters	15
5. H2 steam pipe flow - Excessive flow rate	Overheating	Excessive vapour in the system, action should be necessary to liquefy the vapour or burn it off.	20

RESULTS: HAZOP RISK MATRIX


INITIAL		FREQUENCIES				
		1	2	3	4	5
SEVERITY	1	39	19	25	0	0
	2	12	13	15	0	0
	3	13	36	2	0	2
	4	0	11	5	0	0
	5	0	77	80	6	0



AFTER IMPROVEMENTS		FREQUENCIES				
		1	2	3	4	5
SEVERITY	1	63	15	9	3	0
	2	20	53	13	0	0
	3	6	11	2	0	0
	4	10	110	6	5	0
	5	24	5	0	0	0



TOTAL INITIAL	
Green	172
Yellow	95
Red	88



TOTAL AFTER	
Green	227
Yellow	123
Red	5

**BE
SAFE**

HAZID: Example scenarios



SCENARIO 1: DEVELOPMENT	CONSEQUENCES	RISK
Possibility of line breakage and supply hose breakage. Ship movement leading to leakage of LH2. Worst case scenario risk of fire or explosion.	Damage to persons. Damage to equipment or elements (possible cascading failures). Damage to the environment due to contamination.	15
SCENARIO 1: CONTROL MEASURES		
Limit of unloading operations according to port regulations. Breakaway system (ERS). Continuous monitoring by the ship. Periodic check of the mooring system (checklist).		8
SCENARIO 3: DEVELOPMENT	CONSEQUENCES	
Design line pressure between ESD valve and dry coupling exceeded due to loss of instrumentation air in the valves. Mechanical integrity at risk with LH2 leakage and possibility of fire or explosion.	Damage to persons. Damage to equipment or elements (possible cascading failures). Damage to the environment due to contamination.	20
SCENARIO 3: CONTROL MEASURES		
ESD warning on local panel. Operator must stop operation.		15

RESULTS: HAZID RISK MATRIX

$$\text{RISK} = \text{FREQUENCY} \times \text{SEVERITY}$$

INITIAL MATRIX	RISK MATRIX		FREQUENCIES				
			1	2	3	4	5
	SEVERITY	1	0	0	0	0	0
		2	0	0	1	2	11
		3	0	1	7	4	22
		4	0	2	4	2	3
5		0	11	22	3	0	

MATRIX AFTER IMPROVEM ENTS	RISK MATRIX		FREQUENCIES				
			1	2	3	4	5
	SEVERITY	1	2	1	4	15	19
		2	1	15	3	5	2
		3	4	3	0	0	1
		4	15	5	0	0	0
		5	19	2	1	0	0



TOTALIZERS	
RED	52
YELLOW	41
GREEN	2



TOTALIZERS	
RED	2
YELLOW	14
GREEN	101

RESULTS

- **Risk Analysis for LH2 Unloading Operations**
- **Key Risks Identified:** Hydrogen leaks, ignition and explosion hazards, overpressure, cryogenic system failures, and atmospheric oxygen liquefaction.
- **Mitigation Measures:**
 - System segmentation with automatic valves and pressure relief systems.
 - Automation and control with interlocks and redundancy in sensors.
 - Overpressure management and evacuation circuits.
 - Continuous monitoring of the vacuum in cryogenic pipes.
- **Results:**
 - HAZOP: Reduced high-risk scenarios from 88 to 5.
 - HAZID: Reduced high-risk scenarios from 52 to 2.
 - FMEA: Qualitative failure identification.

CONCLUSIONS AND FUTURE LINES

- **Conclusions:**

Enhanced safety through advanced leak detection, compartmentalization, and GCU redundancy.

Further quantitative risk analysis, including the application of machine learning techniques, is needed for critical scenarios.

- **Future Lines:**

New tools based on Artificial Intelligence, own developments.



**64º Congreso Internacional
de Ingeniería Naval e Industria Marítima**

Gijón 26-28 de marzo de 2025

La industria naval y marítima
como motor de la economía azul.
Por un futuro sostenible para todos.



**Escuela
Técnica
Superior**

**Ingeniería
Naval y
Oceánica**



Thank you very much for your attention
- Muchas gracias por su atención -

Naval Technology Research Group - UPCT

PHD. Student: Julián Sánchez Sánchez

Mr. José Pellitero Pérez

Dr. Carlos Mascaraque-Ramírez

Dr. José Enrique Gutiérrez Romero

WEB: <https://www.upct.es/grupos/tecnaval/>



**Universidad
Politécnica
de Cartagena**